

IEC TC57 WG10 Future Work - WG10 Future Work #5935

Extension of CDC ASG

08/09/2022 08:12 AM - Vladan Cvejic

Status: New	Start date: 09/20/2021
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category:	Estimated time: 0.00 hour
Target version:	Standard(s): IEC 61850-7-3
Source: MH	Needs More Information: No
TF Unique ID: 13 # MH	Assigned TF: 61850-7-3
WG10 Proposal:	Target edition: Next
Discuss in Upcoming Meeting: No	
Short Proposal:	
Description CDC ASG contains 'minVal' and 'maxVal' to limit the permissible value of 'setMag'. These values typically reflect the limits of the device application software. Users require to create additional, more restrictive limit values, to be able to define application specific ranges. It shall be possible to define limit values different for each setting group.	
Related issues: Copied from IEC 61850 User Feedback Task Force - Improvement #5089: Extension... Resolved 09/20/2021 01/20/2022	

History

#1 - 08/09/2022 08:12 AM - Vladan Cvejic

- Copied from Improvement #5089: Extension of CDC ASG added

#2 - 06/21/2023 02:20 AM - Vladan Cvejic

- Tracker changed from WG10FutureWork to WG10 Future Work
- Due date deleted (01/20/2022)
- Needs More Information set to No
- Target edition set to Edition 3
- Assigned TF 61850-7-3 added

#3 - 06/21/2023 02:31 AM - Vladan Cvejic

- Standard(s) changed from IEC 61850 7-3 Ed2.1 to IEC 61850-7-3

#4 - 10/26/2023 02:37 AM - Vladan Cvejic

- Target edition changed from Edition 3 to Not assigned

#5 - 02/08/2024 04:51 AM - Vladan Cvejic

- Target edition changed from Not assigned to Next