

IEC 61850 Certificate - IEC 61850 Certificate #5949

e2TANGO-800

08/16/2022 06:35 AM - Herbert Falk

Status:	Approved	Test Document:	ED2_Server_TP2.0.5_Amd1.1_v2.1.0
Priority:	Normal	Certificate Name:	22-2964_DNV_Elektrometal_e2TANGO-800andVariants_ServerEd2_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	5FC5CDFF5379A77970B391F2B2CC894EBAF81904CACDA53265AF26EF2F4B568B
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Elektrometal Energetyka SA	Vendor Artifact Hash:	
Address:	67 Dzialkowa Street, 02-234 Warsaw Poland	Umbrella Organization:	
Product:	e2TANGO-800	Optional Reservation Test:	Yes
HW Version:	2.0	Serial Number:	13080-00008632-22-0
SW Version:	1.7	Publisher Legacy Variants:	-
Key Words:	Bay Controller, Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	08/16/2022	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description e2TANGO-800 Feeder Protection Relay			

History

#1 - 09/07/2022 10:04 AM - Herbert Falk

- File 22-2964_DNV_Elektrometal_e2TANGO-800andVariants_ServerEd2_Certificate.pdf added

Files

22-2964_DNV_Elektrometal_e2TANGO-800andVariants_ServerEd2_Certificate.pdf 09/07/2022

Herbert Falk