

IEC 61850 User Feedback Task Force - Feature #596

An IED declares constraints that are not machine processable

02/03/2021 02:07 PM - Herbert Falk

Status: Closed	Start date:
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category: Out of Scope	Estimated time: 0.00 hour
Target version:	To discuss in WG10:
ID: 1710	Short Proposal: Do we have a better way of declaring this restrictions?
Source: IOP_2019	Standard(s):
TF Unique ID: 1710 # IOP_2019	Needs More Information:
WG10 Proposal: The only way to expose the restrictions is to provide different ICD files.	Assigned TF:
Estimated Completion:	
Discuss in Upcoming Meeting: No	

Description

An IED declares the following constraints, that are not machine processable, in "desc" attributes:
<AccessPoint name="ETH_1" desc="Ethernet 1 Port, WARNING: If PRP redundancy is used this access point is unavailable">
<SampledValueControl name="MMSVCB02" desc="Only 2 streams can be enabled simultaneously" ...>

History

#1 - 02/11/2021 06:43 AM - Vladan Cvejic

- Subject changed from An IED declares the following constraints, that are not machine processable, in "desc" attributes: <AccessPoint name="ETH_1" desc="Ethernet 1 Port, WARNING: If PRP redundancy is used this access point is unavailable"> to An IED declares constraints that are not machine processable
- Status changed from New to Closed
- Discuss in Upcoming Meeting set to No

Checking done.