

IEC 61850 Certificate - IEC 61850 Certificate #5962

Siemens SIPROTEC 7SJ66 Multifunction protection Relay

09/09/2022 09:26 AM - Herbert Falk

Status:	Approved	Test Document:	UCATestProceduresServer61850-8-1Ed2_Rev2p0p5.pdf
Priority:	Normal	Certificate Name:	22-3104_DNV_Siemens_7SJ66_ServerEd2_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	420A685EDB27B5CB94FACE9AB4E832C74EBFA2ABBCF73FF2C86C932E936A2E8E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens AG, SI EA	Vendor Artifact Hash:	
Address:	Wernerwerkdamm 5 13629 Berlin Germany	Umbrella Organization:	
Product:	SIPROTEC 7SJ66	Optional Reservation Test:	No
HW Version:	S/N: GF2103502856	Serial Number:	
SW Version:	4.40	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	09/09/2022	Subscriber Preferred Rates:	-
Standards Tested:	61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 09/12/2022 06:38 AM - Herbert Falk

- HW Version changed from 4.40 to S/N: GF2103502856

- SW Version changed from S/N: GF2103502856 to 4.40

Files

22-3104_DNV_Siemens_7SJ66_ServerEd2_Certificate.pdf	123 KB	09/09/2022	Herbert Falk
---	--------	------------	--------------