

IEC TC57 WG10 Future Work - WG10 Future Work #5964

Incorrect Attribute type of TrgOp

09/13/2022 07:37 AM - Joel Greene

Status: New	Start date: 09/13/2022
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category:	Estimated time: 0.00 hour
Target version:	Standard(s): IEC 61850-7-2
Source: Tissue DB	Needs More Information: No
TF Unique ID:	Assigned TF: 61850-7-2
WG10 Proposal:	Target edition: Next
Discuss in Upcoming Meeting: No	
Short Proposal:	

Description

According to Table 51, attribute "TrgOp" has type "TrgOpKind".
But 61850-7-2 (and its NSD file) hasn't got any enumeration with name "TrgOpKind".

<https://iec61850.tissue-db.com/tissue/1747>

Proposal descriptions

Add Attribute type "TrgOpKind" (enumeration).

History

#1 - 06/21/2023 01:49 AM - Vladan Cvejic

- Tracker changed from WG10FutureWork to WG10 Future Work
- Source deleted (tissue 1747)
- Discuss in Upcoming Meeting deleted (No)
- Proposal descriptions updated

#2 - 06/21/2023 02:10 AM - Vladan Cvejic

- Source set to Tissue DB
- Discuss in Upcoming Meeting set to No
- Proposal descriptions updated
- Needs More Information set to No

#3 - 10/26/2023 02:37 AM - Vladan Cvejic

- Target edition set to Not assigned

#4 - 02/08/2024 04:23 AM - Vladan Cvejic

- Target edition changed from Not assigned to Next
- Assigned TF 61850-7-2 added

#5 - 02/08/2024 04:24 AM - Vladan Cvejic

- Standard(s) set to IEC 61850-7-2