

# IEC 61850 Certificate - IEC 61850 Certificate #5969

## VITZRO VIPAM-CU Edition 2 Server

09/20/2022 06:33 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	22-052895-01-1_VITZRO EM_VIPAM-CU_Server_Ed2_Certification_KTL.PDF
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	506D4CE51A9DF5CF5EF29AE6FF73C125886D1E7D7621F0C66A47D6C397AAC93E
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	VITZRO EM CO., LTD	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	04998, VITZRO GROUP B/D, 7 Neungdong-ro 25-gil, Gwangjin-gu Seoul, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	VIPAM-CU	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	S/N : CU 20220907 /OS:Embedded Linux	<b>Serial Number:</b>	
<b>SW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Comm, Gateway	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>		<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Description</b>			

### History

#### #1 - 09/20/2022 06:34 AM - Herbert Falk

- 61850 Edition Edition 2 added

- 61850 Edition deleted (Edition 2 Amd 1)

#### #2 - 09/22/2022 07:32 AM - Herbert Falk

- Test Procedure Version changed from 2.0.8 to 2.0.6

### Files

22-052895-01-1\_VITZRO EM\_VIPAM-CU\_Server\_Ed2\_Certification\_KTL.PDF

09/20/2022

Herbert Falk