

WG13 Issues - CIM Issues #5977

Cardinality of PowerSystemResource to Location

09/21/2022 10:03 AM - Martin Miller

Status:	New		
Priority:	Normal		
Target version:			
Author/Contact Info:		Standard(s):	61968-13, 61968-11, 61970-600-2
Base Release:		Version:	2
Solution to be Applied To:		Clause:	
Solution Version:		Sub-Clause:	
Solution Applied By:		Paragraph:	
Completion Date:		Table:	
CIM Keywords:		Originally Closed in Version:	
Breaking Change:	Yes	Origination Date:	
Breaking Change Description:		Origination ID:	
CIM Impacted Groups:	WG13, WG14	Originally Assigned To:	
Requestor:			
Description			
The cardinality of the relationship from PowerSystemResource to Location is 0..1. This prevents a PowerSystemResource from having both a ServiceLocation and a MaintenanceLocation. It also prevents a PowerSystemResource from having PositionPoint coordinates that are part of two different CoordinateSystems.			
Proposed Solution			
Increase the cardinality to 0..*			

History

#1 - 02/28/2024 10:49 AM - Chavdar Ivanov

- Standard(s) changed from 61968-13 to 61968-13, 61968-11, 61970-600-2