

IEC 61850 User Feedback Task Force - Support #607

LPHD.Sim management

02/15/2021 10:10 AM - Carlos Rodriguez del Castillo

Status:	In Progress	Start date:	12/02/2020
Priority:	Normal	Due date:	
Assignee:		% Done:	0%
Category:	Standard clarification required	Estimated time:	0.00 hour
Target version:		To discuss in WG10:	No
ID:	6	Short Proposal:	
Source:	H30	Standard(s):	IEC 61850-80-6 (90-2)
TF Unique ID:	6 # H30	Needs More Information:	
WG10 Proposal:		Assigned TF:	
Estimated Completion:			
Discuss in Upcoming Meeting:	No		

Description

What should be the LPHD.Sim management:

- When the IED has multiple LPHD instances
- When the IED is a proxy

Proposal descriptions

LPHD.Sim will be the same in all LPHD instances of the same IED (closed)
For the proxy, send the question to 80-6 task force to see if they have address it in his work.

History

#1 - 02/15/2021 10:10 AM - Carlos Rodriguez del Castillo

- Discuss in Upcoming Meeting changed from No to Yes

#2 - 02/16/2021 02:26 AM - Carlos Rodriguez del Castillo

- ID changed from 3 to 6
- TF Unique ID changed from 3 # H30 to 6 # H30

#3 - 02/16/2021 09:47 AM - Carlos Rodriguez del Castillo

- Status changed from New to In Progress
- Standard(s) set to IEC 61850-80-6 (90-2)
- Proposal descriptions updated
- To discuss in WG10 set to No

#4 - 06/21/2022 02:09 AM - Vladan Cvejic

- Discuss in Upcoming Meeting changed from Yes to No