

# IEC 61850 Certificate - IEC 61850 Certificate #6141

## FOX612 with BIGO1 IEC61850 interface Server Edition 2

09/22/2022 07:27 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	1KHL050136_IEC61850ConformanceCertificate_ServerEd2_FOX612BIGO1_R16A07.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	6D28DA6C9510A863B41FEF5E1C80A53EC1E4742B2ED5EAAA772C1815A58F90F4
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Hitachi Energy Switzerland Ltd	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Communication Networks CH-5400 Baden/Switzerland	<b>Umbrella Organization:</b>	
<b>Product:</b>	FOX612 with BIGO1 IEC61850 interface	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	R16A07	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Distance, Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>		<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Hitachi Energy Switzerland Ltd(B)		
<b>Description</b>			
FOX612 with BIGO1 IEC61850 interface			

### History

#1 - 09/22/2022 07:28 PM - Herbert Falk

- Current Test Lab Name changed from ABB Switzerland Ltd. (B) to Hitachi Energy Switzerland Ltd(B)

### Files

1KHL050136\_IEC61850ConformanceCertificate\_ServerEd2\_FOX612BIGO1\_R16A07.pdf 09/23/2022

Herbert Falk