

## Server - Issues #6142

### TemplatePics\_Ed1Ed2Ed2p1\_Excel\_rev3p1 contains wrong comment for T2

09/27/2022 07:02 AM - christian zehnder

<b>Status:</b>	Closed	<b>Due date:</b>	03/07/2023
<b>Priority:</b>	Normal		
<b>Assignee:</b>	Joel Greene		
<b>Category:</b>			
<b>Target version:</b>			
<b>Discuss in Upcoming Meeting:</b>	No	<b>Updated Test Document:</b>	
<b>Clause Reference:</b>		<b>Test Case ID:</b>	
<b>61850 Standard:</b>	7-2	<b>Closed Reason:</b>	--Not Set--
<b>Triggering Tissue:</b>		<b>Triggering Tissue 2:</b>	
<b>Final Decision:</b>		<b>Triggering Tissue 3:</b>	
<b>Initial Test Document:</b>			
<b>Description</b>			
Assume its a typo in the latest PICS template on ACSI Service tab for T2:			
T3 (μs) (<= 25 μs),      15 <= T3 < 18			
T4 (μs) (<= 25 μs),      18 <= T3 < 19			
According 7-2:2010 and 2020 T4 is 4us not 25:			
T4 (μs) (<= 4 μs),      18 <= T3 < 19			

#### History

##### #1 - 10/04/2022 08:43 AM - IEC 61850 TPWG

- Due date set to 10/18/2022
- Status changed from New to In Progress
- Assignee set to Joel Greene

Agreed, typo to be fixed.

##### #2 - 10/18/2022 08:36 AM - IEC 61850 TPWG

- Due date changed from 10/18/2022 to 11/01/2022

PICS template to be updated.

##### #3 - 11/29/2022 08:33 AM - IEC 61850 TPWG

- Due date changed from 11/01/2022 to 12/13/2022

##### #4 - 12/13/2022 08:39 AM - Herbert Falk

- Due date changed from 12/13/2022 to 01/10/2023

##### #5 - 01/10/2023 07:17 AM - IEC 61850 TPWG

- Due date changed from 01/10/2023 to 01/24/2023

##### #6 - 02/21/2023 08:17 AM - IEC 61850 TPWG

- Due date changed from 01/24/2023 to 02/07/2023

TemplatePics\_Ed1Ed2Ed2p1\_Excel\_rev3p0 has been uploaded to the SharePoint. Please verify if this resolves the issue.

TemplatePics\_Ed1Ed2Ed2p1\_Excel\_rev3p1 has not been located.

**#7 - 02/21/2023 08:17 AM - IEC 61850 TPWG**

- *Due date changed from 02/07/2023 to 03/07/2023*

**#8 - 03/21/2023 08:10 AM - IEC 61850 TPWG**

- *Status changed from In Progress to Closed*

updated template posted.