

# IEC 61850 Certificate - IEC 61850 Certificate #6152

## xGrids Transfer YH-ISD

10/11/2022 01:12 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Client Test Procedures version 1.2
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	22-053264-01-1_YouHo_YH-ISD_Client_Ed2_TP_1p2_Certificate_KTL.PDF
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	CF59C95B5C579BB98083DBCF140B2186AFDD2B814B67EE570F717ECAFOEB8B4F
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	YOUHO Electric Ind CO., Ltd	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	39-42, 1253 BEON-GIL, GWONYUL-RO, BAEKSEOK-EUP, YANGJU-SI, GYEONGGI-DO, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	xGrids Transfe YH-ISD	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	HPE DL380 Gen10 8LFF NC CTO Svr	<b>Serial Number:</b>	
<b>SW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	HMI	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	1.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	10/11/2022	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Description</b>			
Tested on (CentOS) Oracle Linux Server release 8.5			

### Files

22-053264-01-1\_YouHo\_YH-ISD\_Client\_Ed2\_TP\_1p2\_Certificate\_KTL.PDF

10/11/2022

Herbert Falk