

IEC TC57 WG10 Future Work - WG10 Future Work #6154

<https://iec61850.tissue-db.com/tissue/1698> AnOut in GAPC

10/18/2022 07:40 AM - Henry Dawidczak

Status: New	Start date: 10/18/2022
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category:	Estimated time: 0.00 hour
Target version:	Standard(s): IEC 61850-7-4
Source: Tissue DB	Needs More Information: No
TF Unique ID:	Assigned TF: 61850-7-4
WG10 Proposal:	Target edition: Next
Discuss in Upcoming Meeting: No	
Short Proposal:	
Description Add a new data object AnOut of type APC to Logical Node GAPC.	

History

#1 - 06/21/2023 01:48 AM - Vladan Cvejic

- Tracker changed from WG10FutureWork to WG10 Future Work
- Source deleted (Tissue DB)
- Discuss in Upcoming Meeting deleted (No)

#2 - 06/21/2023 02:06 AM - Vladan Cvejic

- Source set to Tissue DB
- Discuss in Upcoming Meeting set to No
- Needs More Information set to No

#3 - 10/26/2023 02:37 AM - Vladan Cvejic

- Target edition set to Not assigned

#4 - 10/26/2023 05:19 AM - Vladan Cvejic

- Standard(s) set to IEC 61850-7-4
- Target edition changed from Not assigned to Next
- Assigned TF 61850-7-4 added