

IEC TC57 WG10 Future Work - WG10 Future Work #6155

<https://iec61850.tissue-db.com/tissue/1706> Missing LN for Miniature Circuit Breaker (MCB)

10/18/2022 07:43 AM - Henry Dawidczak

| | | | |
|-------------------------------------|-----------|--------------------------------|--------------------|
| Status: | New | Start date: | 10/18/2022 |
| Priority: | Normal | Due date: | |
| Assignee: | | % Done: | 0% |
| Category: | | Estimated time: | 0.00 hour |
| Target version: | | Standard(s): | TR IEC 61850-7-500 |
| Source: | Tissue DB | Needs More Information: | No |
| TF Unique ID: | | Assigned TF: | 61850-7-500 Ed2 |
| WG10 Proposal: | | Target edition: | Next |
| Discuss in Upcoming Meeting: | No | | |
| Short Proposal: | | | |

Description

Missing Logical Node for modeling a Miniature Circuit Breaker (MCB). A MCB can be operated many times compared to XFUS which only can be opened once.

History

#1 - 06/21/2023 01:48 AM - Vladan Cvejic

- Tracker changed from WG10FutureWork to WG10 Future Work
- Source deleted (Tissue DB)
- Discuss in Upcoming Meeting deleted (No)

#2 - 06/21/2023 02:06 AM - Vladan Cvejic

- Source set to Tissue DB
- Discuss in Upcoming Meeting set to No
- Needs More Information set to No

#3 - 10/26/2023 02:37 AM - Vladan Cvejic

- Target edition set to Not assigned

#4 - 10/26/2023 05:17 AM - Vladan Cvejic

- Standard(s) set to TR IEC 61850-7-5
- Target edition changed from Not assigned to Next
- Assigned TF 61850-7-5 added

#5 - 10/26/2023 05:19 AM - Vladan Cvejic

- Standard(s) changed from TR IEC 61850-7-5 to TR IEC 61850-7-500
- Assigned TF 61850-7-500 Ed2 added
- Assigned TF deleted (61850-7-5)