

Server - Issues #6157

sCnf/sMdl not applicable for test equipment

10/18/2022 07:57 AM - Richard Schimmel

Status:	Closed	Due date:	11/15/2022
Priority:	Normal		
Assignee:	Richard Schimmel		
Category:			
Target version:			
Discuss in Upcoming Meeting:	No	Updated Test Document:	TP1.3
Clause Reference:		Test Case ID:	
61850 Standard:	6	Closed Reason:	Test Procedure Update
Triggering Tissue:		Triggering Tissue 2:	
Final Decision:		Triggering Tissue 3:	
Initial Test Document:	Amd1 TP1.2		
Description PIXIT As9 indicates the DUT is test equipment or not. Test equipment has no ICD file. Test equipment imports existing SCD/IID from other manufacturers. For Amd1 we required the DUT has an ICT tool to export IID/ICD and import SCD file. Test equipment only imports SCD file. We propose that for test equipment all the sCnf/sMdl test cases are not applicable, except "import SCD" sCnf5 For example add in clause A2 and A3 a general paragraph: The following test cases are not applicable for test equipment			

History

#1 - 11/01/2022 08:22 AM - IEC 61850 TPWG

- Due date set to 11/15/2022
- Status changed from New to In Progress
- Assignee set to Richard Schimmel

Accepted.

Add in clause A2 and A3 a general paragraph: The following test cases are not applicable for test equipment, conditional on PIXIT As9.

Richard to draft.

#2 - 11/29/2022 08:02 AM - Richard Schimmel

- File Solution to redmine 6157 test equipment.docx added

add solution

#3 - 11/29/2022 08:37 AM - IEC 61850 TPWG

- Status changed from In Progress to Resolved
- Closed Reason Test Procedure Update added
- Closed Reason deleted (--Not Set--)

#4 - 03/01/2024 09:57 AM - Richard Schimmel

- Status changed from Resolved to Closed
- Updated Test Document set to TP1.3

Files

Solution to redmine 6157 test equipment.docx	21.3 KB	11/29/2022	Richard Schimmel
--	---------	------------	------------------