

IEC TC57 WG10 Future Work - WG10 Future Work #6160

<https://iec61850.tissue-db.com/tissue/1796> LPHD.PwrSupAlm as Omulti

10/18/2022 08:11 AM - Henry Dawidczak

<b>Status:</b>	New	<b>Start date:</b>	10/18/2022
<b>Priority:</b>	Normal	<b>Due date:</b>	
<b>Assignee:</b>		<b>% Done:</b>	0%
<b>Category:</b>		<b>Estimated time:</b>	0.00 hour
<b>Target version:</b>		<b>Standard(s):</b>	TR IEC 61850-90-29
<b>Source:</b>	Tissue DB	<b>Needs More Information:</b>	No
<b>TF Unique ID:</b>		<b>Assigned TF:</b>	61850-90-29 - Physical resource management
<b>WG10 Proposal:</b>		<b>Target edition:</b>	Next
<b>Discuss in Upcoming Meeting:</b>	No		
<b>Short Proposal:</b>			
<b>Description</b>			
Tissue is about redundant PS. "Several devices include redundant power supplies. Each power supply can indicate a problem with a signal, but the LPHD only shows one data object called PwrSupAlm."			
TF 90-29 (about Modelling of Physical resources) has started the discussion of model of power supply and should provide a agreed proposal.			

History

- #1 - 06/21/2023 01:48 AM - Vladan Cvejic
  - Tracker changed from WG10FutureWork to WG10 Future Work
  - Source deleted (Tissue DB)
  - Discuss in Upcoming Meeting deleted (No)
- #2 - 06/21/2023 02:05 AM - Vladan Cvejic
  - Source set to Tissue DB
  - Discuss in Upcoming Meeting set to No
  - Needs More Information set to No
- #3 - 10/26/2023 02:37 AM - Vladan Cvejic
  - Target edition set to Not assigned
- #4 - 10/26/2023 05:13 AM - Vladan Cvejic
  - Standard(s) set to TR IEC 61850-90-29
  - Target edition changed from Not assigned to Next
  - Assigned TF 61850-90-29 - Physical resource management added