

IEC TC57 WG10 Future Work - WG10 Future Work #6163

<https://iec61850.tissue-db.com/tissue/1804> - When e.g. LocSta = false, result of command to switch DO Mod with "station-control" not clear.

10/18/2022 08:21 AM - Henry Dawidczak

Status: New	Start date: 10/18/2022
Priority: Normal	Due date:
Assignee:	% Done: 0%
Category:	Estimated time: 0.00 hour
Target version:	
Source: Tissue DB	Standard(s): TR IEC 61850-7-5
TF Unique ID:	Needs More Information: No
WG10 Proposal:	Assigned TF: 61850-7-5
Discuss in Upcoming Meeting: No	Target edition: Next
Short Proposal:	
Description	
Topic will be discussed in TF7-5/7-500. Future improvement comes from future TR 7-500.	
Proposal descriptions	
LocSta is to be described in 7-5. To be incorporated in Annex B in 7-4.	

History

#1 - 06/21/2023 01:48 AM - Vladan Cvejic

- Tracker changed from WG10FutureWork to WG10 Future Work
- Source deleted (Tissue DB)
- Discuss in Upcoming Meeting deleted (No)

#2 - 06/21/2023 02:04 AM - Vladan Cvejic

- Source set to Tissue DB
- Discuss in Upcoming Meeting set to No
- Needs More Information set to No

#3 - 10/26/2023 02:37 AM - Vladan Cvejic

- Target edition set to Not assigned

#4 - 10/26/2023 05:03 AM - Vladan Cvejic

- Standard(s) set to TR IEC 61850-7-5
- Target edition changed from Not assigned to Next
- Assigned TF 61850-7-5 added

#5 - 10/26/2023 05:06 AM - Vladan Cvejic

- Proposal descriptions updated