

## Server - Issues #6169

### verify IED can subscribe to GOOSE/SV from ServerAt accesspoint

10/20/2022 08:32 AM - Richard Schimmel

<b>Status:</b> Closed	<b>Due date:</b> 01/24/2023
<b>Priority:</b> Normal	
<b>Assignee:</b> Richard Schimmel	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b> TP1.3
<b>Clause Reference:</b>	<b>Test Case ID:</b> sGos16 (new), sSvs17 (new)
<b>61850 Standard:</b> 8-1, 9-2	<b>Closed Reason:</b> --Not Set--
<b>Triggering Tissue:</b>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b>	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b> Amd1 TP1.2	
<b>Description</b> At the IOP in Milan it was detected that some devices could not subscribe to GOOSE/SV from an IED ServerAt accesspoint. We already have a test case sMdl27 but we also need to verify the actual subscription communication. We propose to add new GOOSE subscribe test case and also a new for SV subscribe	

#### History

##### #1 - 11/01/2022 08:23 AM - IEC 61850 TPWG

- Due date set to 12/13/2022
- Status changed from New to In Progress
- Assignee set to Richard Schimmel

Accepted.

Richard to draft.

##### #2 - 12/13/2022 08:39 AM - Herbert Falk

- Due date changed from 12/13/2022 to 01/10/2023

##### #3 - 01/09/2023 07:46 AM - Richard Schimmel

- File Solution to redmine 6169 sGos16.docx added
- Test Case ID changed from new sGos, new sSvs to sGos16 (new), sSvs17 (new)

Added solution

##### #4 - 01/10/2023 08:35 AM - IEC 61850 TPWG

- Due date changed from 01/10/2023 to 01/24/2023
- Status changed from In Progress to Resolved

proposal accepted

##### #5 - 03/01/2024 09:57 AM - Richard Schimmel

- Status changed from Resolved to Closed
- Updated Test Document set to TP1.3

#### Files

