

# IEC 61850 Certificate - IEC 61850 Certificate #6171

## REX640 Protection and Control Relay

10/27/2022 12:12 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 with Amendment 1 Server Test Procedures version 1.1.
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	22-3007_DNV_ABB_REX640_ServerEd2Amd1_Certificate.pdf
<b>61850 Edition:</b>	Edition 2 Amd 1	<b>Certificate Hash:</b>	SHA256: 1D9326591F8598251A9D3078A376733 35B4FDC748B3686D
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	ABB Oy	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Distribution Solutions Muottitie 2A FI-65101 Vaasa Finland	<b>Umbrella Organization:</b>	
<b>Product:</b>	REX640 Protection and Control Relay	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	S/N: 1VHR81010050 Product Version 1.	<b>Serial Number:</b>	
<b>SW Version:</b>	1.3	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	1.1	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1a), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time sync PTP (B13b), Time sync SNTP (B13a), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	10/27/2022	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			

### Files

22-3007_DNV_ABB_REX640_ServerEd2Amd1_Certificate.pdf	116 KB	10/27/2022	Herbert Falk
--	--------	------------	--------------