

IEC 61850 Certificate - IEC 61850 Certificate #6173

FTU PNC Technologies Edition 2 Server

11/02/2022 07:36 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	22-054084-01-1_PNCTech_FTU_Server_Ed2_Certification_KTL.PDF
61850 Edition:	Edition 2	Certificate Hash:	SHA256: E00795AB1BA52F393FF8213F29CA27 2820768722AB00FA11B4A6A26F43F01 5F8
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	PNC Technologies Co., Ltd	Vendor Artifact Hash:	
Address:	62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si, Gyeonggi-do, 14042, Republic of Korea	Umbrella Organization:	
Product:	FTU	Optional Reservation Test:	Yes
HW Version:		Serial Number:	
SW Version:	6.0 SYS/BIOS 6.42.1.20 (Ti)	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	11/02/2022	Subscriber Preferred Rates:	-
Standards Tested:	61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			

Files

22-054084-01-1_PNCTech_FTU_Server_Ed2_Certification_KTL.PDF 100 KB 11/02/2022 Herbert Falk