

IEC 61850 Certificate - IEC 61850 Certificate #6177

PNC FTU-P200T Server Edition 2

11/09/2022 06:59 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	22-054084-01-3_PNCTech_FTU-P200T_Server_Ed2_Certification_KTL.PDF
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 2234ACC958504D9D3017AAB180F802 B670302ACB9A5063990A18B528DB64 0958
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	PNC Technologies Co., Ltd.	Vendor Artifact Hash:	
Address:	62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si, Gyeonggi-do, 14042, Republic of Korea	Umbrella Organization:	
Product:	FTU-P200T	Optional Reservation Test:	No
HW Version:	FTU-P200T	Serial Number:	FTU-P200T-2210-0001
SW Version:	6.0	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	11/09/2022	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		

Description

History

#1 - 11/09/2022 07:00 AM - Herbert Falk

- Key Words Relay added

Files

22-054084-01-3_PNCTech_FTU-P200T_Server_Ed2_Certification_KTL.PDF

11/09/2022

Herbert Falk