

IEC TC57 WG10 Future Work - WG10 Future Work #6185

SCL Need to differentiate the difference in the number of GOOSE vs R-GOOSE

11/22/2022 08:24 AM - Herbert Falk

Status:	New	Start date:	11/22/2022
Priority:	Normal	Due date:	
Assignee:		% Done:	0%
Category:		Estimated time:	0.00 hour
Target version:		Standard(s):	IEC 61850-6
Source:	2022 IOP	Needs More Information:	No
TF Unique ID:		Assigned TF:	61850-6
WG10 Proposal:		Target edition:	Next
Discuss in Upcoming Meeting:	No		
Short Proposal:			

Description

From the iec61850-6 standard, there is no attribute to define maximum no of R-GOOSE publishers supported. R-GOOSE capability need not be same as NORM GOOSE. As R-GOOSE might be used only for inter substation communication Believe there should be a differentiation in the service section between GOOSE and R-GOOSE support.

History

#1 - 11/22/2022 08:26 AM - Herbert Falk

- Description updated

#2 - 06/15/2023 11:59 AM - Joel Greene

- Target edition set to Edition 3

#3 - 06/21/2023 01:48 AM - Vladan Cvejic

- Tracker changed from WG10FutureWork to WG10 Future Work

- Source deleted (2022 IOP)

- Discuss in Upcoming Meeting deleted (No)

- Needs More Information deleted (No)

#4 - 06/21/2023 02:03 AM - Vladan Cvejic

- Source set to 2022 IOP

- Discuss in Upcoming Meeting set to No

- Needs More Information set to No

#5 - 10/26/2023 02:37 AM - Vladan Cvejic

- Target edition changed from Edition 3 to Not assigned

#6 - 10/26/2023 05:01 AM - Vladan Cvejic

- Standard(s) set to IEC 61850-6

- Target edition changed from Not assigned to Next

- Assigned TF 61850-6 added

Files

20220902_Benson_Chacko_SEC_RGGOOSE_01.docx

87.4 KB

11/22/2022

Herbert Falk