

# IEC 61850 Certificate - IEC 61850 Certificate #6187

## UR N60 Edition 2 Server

11/24/2022 08:18 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.5
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	50745.6UR.807_GE_UR_V8.4_Edition2_Certificate.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: C62A3493502D6A1F88DAB96AF4547C B115292211B78302DEE2679162CB956 B15
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	GE Renewable Energy	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	650 Markland St Markham, ON L6C 0M1, Canada	<b>Umbrella Organization:</b>	
<b>Product:</b>	UR N60	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	8.40	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	11/24/2022	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Grid Automation Laboratories (B)		
<b>Description</b>			
Network Stability and Synchrophasor Measurement Relay			