Server - Issues #6188

sSBOns8 does not consider PIXIT Ct13

11/25/2022 04:33 AM - Thierry Dufaure

Status:	Closed	**Due date:**	12/13/2022
Priority:	Normal		
Assignee:	Richard Schimmel		
Category:			
Target version:			
Discuss in Upcoming Meeting:	Yes	**Updated Test Document:**	TP1.3
Clause Reference:		**Test Case ID:**	sSBOns8
61850 Standard:		**Closed Reason:**	--Not Set---
Triggering Tissue:		**Triggering Tissue 2:**	
Final Decision:		**Triggering Tissue 3:**	
Initial Test Document:	Ed2Amd1 TP1.2		

Description

The test description considers that a cancel service using the service parameter origin.orCat = 1 succeeds.
However the PIXIT Ct13 allows a range check of the service parameters for any control service.
It should be out of scope of the test to fix the order of the test. A device can decide to
- first check the range of the service paremeters
- and then verify the coherency of them vs the configured control model

Or first verify the coherency (and in this particuliar case: ignore the coherency) and then verify the range of allowed value.

I recommend to remove orCat from the list of parmeters, or to use an orCat that is allowed by the device based on PIXIT Ct13.

History

#1 - 11/29/2022 08:32 AM - IEC 61850 TPWG

- Due date set to 12/13/2022

- Status changed from New to In Progress

- Assignee changed from IEC 61850 TPWG to Richard Schimmel

Agree with proposal:

Remove the orCat check from sSBOns8

#2 - 11/29/2022 09:22 AM - Richard Schimmel

- File Solution to redmine 6188 sSBOns8.docx added

- Initial Test Document set to Ed2Amd1 TP1.2

added solution

#3 - 11/30/2022 08:23 AM - Thierry Dufaure

I agree with Richard proposal from Nov, 29.

#4 - 12/13/2022 08:38 AM - Herbert Falk

- Status changed from In Progress to Resolved

Reviewed proposed test procedure during TPWG meeting.

#5 - 03/01/2024 09:58 AM - Richard Schimmel

- Status changed from Resolved to Closed

- Updated Test Document set to TP1.3

Files

Solution to redmine 6188 sSBOns8.docx	21.8 KB	11/29/2022	Richard Schimmel