

IEC 61850 Certificate - IEC 61850 Certificate #6205

SNI 61850 Server Protocol Converter (SNIIT)

01/03/2023 08:08 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.5
Priority:	Normal	Certificate Name:	22TC200875(RT22A2I01018)_SNIIT_Server_Ed2_KERI.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 00645E052E50DF298B945069DECC4D 2590560F59D08B556601F046DE592DA AAD
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	SNIIT Corporation	Vendor Artifact Hash:	
Address:	#711, 172, LS-ro, Gunpyo-si, Gyeonggi-do, Republic of Korea	Umbrella Organization:	
Product:	SNI 61850 Server Protocol Converter	Optional Reservation Test:	Yes
HW Version:	LG notebook gram 16Z90P - OS: Windows 10 Home	Serial Number:	
SW Version:	1.0.0.0	Publisher Legacy Variants:	-
Key Words:	Gateway	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	01/03/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			

History

#1 - 01/19/2023 08:37 AM - Herbert Falk

- 61850 Edition Edition 2 added

- 61850 Edition deleted (Edition 2 Amd 1)

Corrected Edition that was tested.

Files

22TC200875(RT22A2I01018)_SNIIT_Server_Ed2_KERI.pdf	716 KB	01/03/2023	Herbert Falk
--	--------	------------	--------------