

Server - Issues #6206

Type and size of Length field value (TLV) encoding in SV

01/10/2023 08:54 AM - IEC 61850 TPWG

Status: Rejected	Due date: 01/24/2023
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document:
Clause Reference:	Test Case ID: sSvp7
61850 Standard: 9-2	Closed Reason: Duplicate Issue
Triggering Tissue: https://iec61850.tissue-db.com/tissue/1720	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document:	
Description	
Test case needs to be written	

History

#1 - 01/11/2023 06:19 AM - Richard Schimmel

- Status changed from New to Rejected
- Test Case ID set to sSvp7
- Closed Reason Duplicate Issue added
- Closed Reason deleted (--Not Set--)

We already have testcase sSvp7 to verify the DUT uses the minimum length encoding.