

IEC 61850 User Feedback Task Force - Feature #621

New controllable DO in RREC to define the mode of the recloser of the circuit breaker

02/16/2021 01:48 AM - Carlos Rodriguez del Castillo

Status:	In Progress	Start date:	10/23/2020
Priority:	Normal	Due date:	11/24/2020
Assignee:	Carlos Rodriguez del Castillo	% Done:	0%
Category:	Standard extension required	Estimated time:	0.00 hour
Target version:			
ID:	17	To discuss in WG10:	No
Source:	RTE	Short Proposal:	RTE demands a new controllable data object (not only enumerated value)
TF Unique ID:	17 # RTE	Standard(s):	IEC 61850-7-4/7-500
WG10 Proposal:		Needs More Information:	
Estimated Completion:		Assigned TF:	
Discuss in Upcoming Meeting:	No		
Description			
Details: Need to have a new controllable DO (as "RecCycMod") to define the mode of the recloser of the circuit breaker, in LN RREC; and to add new value to enumeration LiveDeadModeKind Mode of recloser should be : live line dead bus, live bus dead line... RTE uses a mode live -line / live bus which is not present in the enumeration.			
Related issues:			
Copied to 61850-7-5 and 61850-7-500 - IEC61850-7-5 #6384: New controllable DO...			New 10/23/2020 11/24/2020

History

#1 - 02/16/2021 01:50 AM - Carlos Rodriguez del Castillo

- Tracker changed from Bug to Feature
- Due date set to 11/24/2020
- Status changed from New to Resolved
- Short Proposal set to To add a new enumerated value to LiveDeadModeKind
- WG10 Proposal set to Accepted to be included in next amendment of 7-4

Discussion during meeting 2020-11-24:

It is RSYN the place. Two points:

- To create a new controllable DO (equivalent to LivDeaMod ENG) or change LivDeaMod to ENC --> We have to handle inside WG10 to decide about the first issue
- To add a new enumerated value to LiveDeadModeKind --> Accepted to update in next amendment of 7-4

#2 - 02/16/2021 01:56 AM - Carlos Rodriguez del Castillo

- Start date changed from 10/07/2020 to 10/23/2020

#3 - 03/02/2021 09:35 AM - Carlos Rodriguez del Castillo

- Assignee set to Carlos Rodriguez del Castillo
- WG10 Proposal changed from Accepted to be included in next amendment of 7-4 to Accepted to be included in next amendment of 7-4 (2.2)
- Discuss in Upcoming Meeting changed from Yes to No
- To discuss in WG10 set to No

2021-03-02: Carlos will contact Dawidczak, Henry to register by himself in the system and Herb will give him the role of developer. After that, Carlos will assign this issue to him.

#4 - 05/11/2021 10:08 AM - Carlos Rodriguez del Castillo

- *Status changed from Resolved to In Progress*
- *Short Proposal changed from To add a new enumerated value to LiveDeadModeKind to RTE demands a new controllable data object (not only enumerated value)*
- *Standard(s) changed from IEC 61850-7-4 to IEC 61850-7-4/7-500*
- *WG10 Proposal deleted (Accepted to be included in next amendment of 7-4 (2.2))*

2021-05-11: To handle this issue in 7-500 together with [#647](#) issue.

#5 - 06/14/2023 08:19 AM - Vladan Cvejic

- *Copied to IEC61850-7-5 #6384: New controllable DO in RREC to define the mode of the recloser of the circuit breaker added*