

# IEC 61850 Certificate - IEC 61850 Certificate #6212

## MiCOM P40 Agile Enhanced P14D

01/12/2023 08:25 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.5
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	CPRI - GE TandD India Limited_CPRI BLRS GRL23TC0001.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 27886AE7B15A06580998AF31E2623B8 9A8348F2E713CA45053B62BCF6D854 203
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	GE T&D INDIA LIMITED	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	19/1, G.S.T. ROAD, PALLAVARAM, CHENNAI -600043, TAMIL NADU, INDIA	<b>Umbrella Organization:</b>	
<b>Product:</b>	MiCOM P40 Agile Enhanced P14D	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	E	<b>Serial Number:</b>	36153218/08/22
<b>SW Version:</b>	03C	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	01/12/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Central Power Research Institute India (A)		
<b>Description</b> FEEDER MANAGEMENT IED			

### Files

CPRI - GE TandD India Limited_CPRI BLRS GRL23TC0001.pdf	931 KB	01/12/2023	Herbert Falk
---	--------	------------	--------------