

Server - Issues #6214

ED2 sCtl14 refer to PIXIT entry Ct16 which is a ED1 only PIXIT entry

01/16/2023 05:45 AM - Hua Qin

Status: Closed	Due date: 02/07/2023
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document: TP1.3
Clause Reference: 20.1 Table 108	Test Case ID: sCtl14
61850 Standard: 7-2	Closed Reason: --Not Set--
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document:	

Description

ED2 test case sCtl14 refers to PIXIT entry Ct16.
Ct16 is the ED1 only entry in the PIXIT template.

According to Figure 42 and Tabl 108,, after the first client sends correct Operate command, there should only be one response, it is Response- with command-already-in-execution. This respond aligns with Sctl14 abstract test case description as well.

It is suggested to remove the PIXIT entry Ct16 from this test case and update the expected result to be reponse- with command-already-in-execution.

History

#1 - 01/24/2023 08:55 AM - IEC 61850 TPWG

- Due date set to 02/07/2023
- Status changed from New to Resolved
- Assignee set to Richard Schimmel

Accepted to remove Ct16 condition.

Reject removing locked-by-other-client

#2 - 03/01/2024 10:00 AM - Richard Schimmel

- Status changed from Resolved to Closed
- Updated Test Document set to TP1.3