

Server - Issues #6227

sDoc5 GSESettings/SMVsettings apply for SendGOOSE/SMVmessage not SetGoCBValues/SetMsvCBValues

01/19/2023 04:26 AM - Richard Schimmel

| | | | |
|--|------------------|-------------------------------|-------------|
| Status: | Closed | Due date: | 02/07/2023 |
| Priority: | Normal | | |
| Assignee: | Richard Schimmel | | |
| Category: | | | |
| Target version: | | | |
| Discuss in Upcoming Meeting: | No | Updated Test Document: | TP1.3 |
| Clause Reference: | | Test Case ID: | |
| 61850 Standard: | 6 | Closed Reason: | --Not Set-- |
| Triggering Tissue: | | Triggering Tissue 2: | |
| Final Decision: | | Triggering Tissue 3: | |
| Initial Test Document: | TP1.2 | | |
| Description | | | |
| GSESettings is related to "S39" SetGoCBValues, but we also need to know if the dataset is configurable or fixed. I propose to change the condition to "S35 publisher" SendGOOSEmessage | | | |
| Same for SMVSettings from S47 S50 to S45 SendSMVmessage | | | |

History

#1 - 01/24/2023 08:44 AM - IEC 61850 TPWG

- Due date set to 02/07/2023
- Status changed from New to Resolved
- Assignee set to Richard Schimmel

Accepted.

#2 - 03/01/2024 10:01 AM - Richard Schimmel

- Status changed from Resolved to Closed
- Updated Test Document set to TP1.3