

IEC 61850 Certificate - IEC 61850 Certificate #6233

SA ICD (Substation Automation Information Connecting Device) ECU-4784

01/30/2023 07:39 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Client Test Procedures version 1.2
Priority:	Normal	Certificate Name:	22-065621-03-1_WOODAM Tech_SA-ICD_Client_Ed2_Certificate_K TL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 18EEB826E27DEF13225C5FE0F5ADD 9BD7CB570A1A3E18D0C3229B6F3659 91655
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	WOODAM TECH CO., LTD	Vendor Artifact Hash:	
Address:	33, Daeposandan 1-ro, Yangchon-eup, Gimpo-si, Gyeonggi-do, Republic of Korea	Umbrella Organization:	
Product:	SA ICD (Substation Automation Information Connecting Device) ECU-4784	Optional Reservation Test:	Yes
HW Version:	ADVANTECH ECU-4784/OS Windows Server 2019 Standard	Serial Number:	WD-ICD2-220001
SW Version:	1.0.0	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:		Subscriber Preferred Variants:	
Approval Date:		Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
SA ICD (Substation Automation Information Connecting Device) ECU-4784			

History

#1 - 01/30/2023 07:40 AM - Herbert Falk

- *Optional Reservation Test changed from No to Yes*

#2 - 02/15/2023 09:53 AM - Herbert Falk

- Certificate Hash changed from SHA256: 315513780314214D3FE38C2AD552E6602D6BAE5EAFE6F3BB9DA2E9B36811BAA7 to SHA256: 18EEB826E27DEF13225C5FE0F5ADD9BD7CB570A1A3E18D0C3229B6F365991655

#3 - 02/15/2023 09:53 AM - Herbert Falk

- File deleted (22-065621-03-1_WOODAM Tech_SA-ICD_Client_Ed2_Certificate_KTL.pdf)

#4 - 02/15/2023 09:53 AM - Herbert Falk

- File 22-065621-03-1_WOODAM Tech_SA-ICD_Client_Ed2_Certificate_KTL.pdf added

Files

22-065621-03-1_WOODAM Tech_SA-ICD_Client_Ed2_Certificate_KTL.pdf	137KB	02/15/2023	Herbert Falk
--	-------	------------	--------------