

IEC 61850 Certificate - IEC 61850 Certificate #6235

SA MD (Substation Automation Monitoring & diagnosis Device) VertexCOM-MD3

01/30/2023 07:50 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 22-065630-06-1_WOODAM Tech_SA MD_Server_Ed2_Certification_KTL.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: 5ABA39E8E07E5B949EEB4BC17A61E D50BD9CD990858920016D9EBC811E58 995EC
Company:	WOODAM TECH CO., LTD	Vendor Artifact File Name:
Address:	33, Daeposandan 1-ro, Yangchon-eup, Gimpo-si, Gyeonggi-do, Republic of Korea	Vendor Artifact Hash:
Product:	SA MD (Substation Automation Monitoring & diagnosis Device) VertexCOM-MD3	Umbrella Organization:
HW Version:	WOODAMTECH VertexCOM-MD3/Windows Server 2019 Standard	Optional Reservation Test: Yes
SW Version:	1.0.0	Serial Number: WD-MD3-220001
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	2.0.6	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	01/30/2023	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 Server Test Procedures version 2.0.6	Time Activated Control:
Description SA MD (Substation Automation Monitoring & diagnosis Device) VertexCOM-MD3		

History

#1 - 02/17/2023 03:58 PM - Herbert Falk

- File deleted (22-065630-06-1_WOODAM Tech_SA MD_Server_Ed2_Certification_KTL.pdf)

#2 - 02/17/2023 03:59 PM - Herbert Falk

- File 22-065630-06-1_WOODAM Tech_SA MD_Server_Ed2_Certification_KTL.pdf added
- Test Procedure Version changed from 2.0.5 to 2.0.6
- Test Document changed from Edition 2 Server Test Procedures version 2.0.5 to Edition 2 Server Test Procedures version 2.0.6
- Certificate Hash changed from SHA256: E21896EB4CC9EC7ACCA13B2EEC00D672A30F054F35D9A426C933746639690FDA to SHA256: 5ABA39E8E07E5B949EEB4BC17A61ED50BDCD990858920016D9EBC811E58995EC

Files

22-065630-06-1_WOODAM Tech_SA MD_Server_Ed2_Certification_KTL.pdf	62.3 KB	02/17/2023	Herbert Falk
---	---------	------------	--------------