IEC 61850 Certificate - IEC 61850 Certificate #6236

SA LID (Substation Automation Local Information processing Device) ECU-4784

01/30/2023 07:55 AM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	22-065635-02-1_WOODAM Tech_SA LID_Server_Ed2_Certification_KTL.pdf
61850 Tested Aspects:	Server	**Certificate Hash:**	SHA256: 39CA5209678AD7175A1BB3A335610E8D97E0F47392418F478B4D3868001FC3B6
Company:	WOODAM TECH CO., LTD.	**Vendor Artifact File Name:**	
Address:	33, Daeposandan 1-ro, Yangchon-eup, Gimpo-si, Gyeonggi-do, Republic of Korea	**Vendor Artifact Hash:**	
Product:	SA LID (Substation Automation Local Information processing Device) ECU-4784	**Umbrella Organization:**	
HW Version:	ADVANTECH ECU-4784/: Windows Server 2019 Standard	**Optional Reservation Test:**	No
SW Version:	1.0.0	**Serial Number:**	WD-LID2-220001
Key Words:		**Publisher Legacy Variants:**	-
Test Procedure Version:	2.0.6	**Publisher Preferred Rates:**	-
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	Herbert Falk	**Subscriber Legacy Variants:**	-
Approval Date:	01/30/2023	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	-
Current Test Lab Name:	Korea Testing Laboratory (A)	**Product Variants:**	
Test Document:	Edition 2 Server Test Procedures version 2.0.6		

Description

SA LID (Substation Automation Local Information processing Device)
ECU-4784

History

#1 - 02/17/2023 04:00 PM - Herbert Falk

- File deleted (22-065635-02-1_WOODAM Tech_SA LID_Server_Ed2_Certification_KTL.pdf)

#2 - 02/17/2023 04:01 PM - Herbert Falk

- File 22-065635-02-1_WOODAM Tech_SA LID_Server_Ed2_Certification_KTL.pdf added

- Test Procedure Version changed from 2.0.5 to 2.0.6

- Test Document changed from Edition 2 Server Test Procedures version 2.0.5 to Edition 2 Server Test Procedures version 2.0.6

- Certificate Hash changed from SHA256: 326717B285C0A676EEA4C2B0D2CC4A57416E0DB5FF80B52003908EBC1CABF8FC to SHA256: 39CA5209678AD7175A1BB3A335610E8D97E0F47392418F478B4D3868001FC3B6

- Standards Tested 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4 added

Files

22-065635-02-1_WOODAM Tech_SA LID_Server_Ed2_Certification_KTL.pdf	63.8 kB	02/17/2023	Herbert Falk