

# IEC 61850 Certificate - IEC 61850 Certificate #6236

## SA LID (Substation Automation Local Information processing Device) ECU-4784

01/30/2023 07:55 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	22-065635-02-1_WOODAM Tech_SA LID_Server_Ed2_Certification_KTL.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 39CA5209678AD7175A1BB3A335610E8D97E0F47392418F478B4D3868001FC3B6
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	WOODAM TECH CO., LTD.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	33, Daeposandan 1-ro, Yangchon-eup, Gimpo-si, Gyeonggi-do, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	SA LID (Substation Automation Local Information processing Device) ECU-4784	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	ADVANTECH ECU-4784/: Windows Server 2019 Standard	<b>Serial Number:</b>	WD-LID2-220001
<b>SW Version:</b>	1.0.0	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	01/30/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Description</b>			
SA LID (Substation Automation Local Information processing Device) ECU-4784			

### History

#1 - 02/17/2023 04:00 PM - Herbert Falk

- File deleted (22-065635-02-1\_WOODAM Tech\_SA LID\_Server\_Ed2\_Certification\_KTL.pdf)

#2 - 02/17/2023 04:01 PM - Herbert Falk

- File 22-065635-02-1\_WOODAM Tech\_SA LID\_Server\_Ed2\_Certification\_KTL.pdf added

- Test Procedure Version changed from 2.0.5 to 2.0.6
- Test Document changed from Edition 2 Server Test Procedures version 2.0.5 to Edition 2 Server Test Procedures version 2.0.6
- Certificate Hash changed from SHA256: 326717B285C0A676EEA4C2B0D2CC4A57416E0DB5FF80B52003908EBC1CABF8FC to SHA256: 39CA5209678AD7175A1BB3A335610E8D97E0F47392418F478B4D3868001FC3B6
- Standards Tested 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4 added

**Files**

---

22-065635-02-1_WOODAM Tech_SA LID_Server_Ed2_Certification_1611.pptx	02/17/2023	Herbert Falk
--	------------	--------------