

## WG14 Part 3 Issues - CIM Issues #6244

### Part 3 should specify that you can use 'updated' verb

01/31/2023 03:31 PM - Martin Bass

<b>Status:</b>	New	
<b>Priority:</b>	Normal	
<b>Target version:</b>		
<b>Author/Contact Info:</b>	martin.bass@hitachienergy.com	<b>Standard(s):</b>
<b>Base Release:</b>	61968-3 edition 3	<b>Version:</b>
<b>Solution to be Applied To:</b>	61968-3 edition 4	<b>Clause:</b>
<b>Solution Version:</b>		<b>Sub-Clause:</b>
<b>Solution Applied By:</b>		<b>Paragraph:</b>
<b>Completion Date:</b>		<b>Table:</b>
<b>CIM Keywords:</b>	61968-Operations	<b>Originally Closed in Version:</b>
<b>Breaking Change:</b>	No	<b>Origination Date:</b>
<b>Breaking Change Description:</b>		<b>Origination ID:</b>
<b>CIM Impacted Groups:</b>	WG14	<b>Originally Assigned To:</b>
<b>Requestor:</b>		
<b>Description</b>		
Edition 3 does not specify that you can use the 'updated' verb that is defined in Part 100 edition 2. This makes it very difficult to implement Part 3 because even though only one element of the XSD has changed, the entire message must be sent when the 'changed' verb is used.		
<b>Proposed Solution</b>		
Update to the document only; no modeling changes needed.		

#### History

#1 - 01/31/2023 03:32 PM - Martin Bass

Provide examples of using the 'updated' verb and updated sequence diagrams.