

# IEC 61850 Certificate - IEC 61850 Certificate #6261

## xGrids Transfer YH-ISD

02/13/2023 07:18 AM - Herbert Falk

<p><b>Status:</b> Approved</p> <p><b>Priority:</b> Normal</p> <p><b>61850 Edition:</b> Edition 2</p> <p><b>61850 Tested Aspects:</b> Server</p> <p><b>Company:</b> YOUHO Electric Ind CO., Ltd.</p> <p><b>Address:</b> 39-42, 1253 BEON-GIL, GWONYUL-RO, BAEKSEOK-EUP, YANGJU-SI, GYEONGGI-DO, Republic of Korea</p> <p><b>Product:</b> xGrids Transfer YH-ISD</p> <p><b>HW Version:</b> HPE DL380</p> <p><b>SW Version:</b> 1.0</p> <p><b>Key Words:</b></p> <p><b>Test Procedure Version:</b> 2.0.6</p> <p><b>IEC 61850 Blocks Certified:</b> Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)</p> <p><b>Certificate/Result Reviewer:</b> Herbert Falk</p> <p><b>Approval Date:</b> 02/13/2023</p> <p><b>Standards Tested:</b> 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1</p> <p><b>Current Test Lab Name:</b> Korea Testing Laboratory (A)</p>	<p><b>Test Document:</b></p> <p><b>Certificate Name:</b> 22-053264-01-2_YouHo_YH-ISD_Server_Ed2_Certification_KTL.pdf</p> <p><b>Certificate Hash:</b> SHA256: 159051AB4DE60B81BDFDF21CFF013E C8E7F6C5703AC68B6B71D8ADF1DEA 935D2</p> <p><b>Vendor Artifact File Name:</b></p> <p><b>Vendor Artifact Hash:</b></p> <p><b>Umbrella Organization:</b></p> <p><b>Optional Reservation Test:</b> Yes</p> <p><b>Serial Number:</b> YHISD-0001</p> <p><b>Publisher Legacy Variants:</b> -</p> <p><b>Publisher Preferred Rates:</b> -</p> <p><b>Publisher Preferred Variants:</b></p> <p><b>Subscriber Legacy Variants:</b> -</p> <p><b>Subscriber Preferred Variants:</b></p> <p><b>Subscriber Preferred Rates:</b> -</p>
<p><b>Description</b></p>	

### Files

22-053264-01-2_YouHo_YH-ISD_Server_Ed2_Certification_KTL.pdf	92.9 KB	02/13/2023	Herbert Falk
--	---------	------------	--------------