

IEC 61850 Certificate - IEC 61850 Certificate #6264

SIPROTEC 5 - 7VU85 High Speed Busbar Transfer

02/14/2023 07:26 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2
Priority:	Normal	Certificate Name:	23-2512_DNV_Siemens_7VU85_Server Ed2Amd1_Certificate.pdf
61850 Edition:	Edition 2 Amd 1	Certificate Hash:	SHA256: 5C85F1B4A30249F4A1E7B8BB5F35A9 E8036DB3508F57FC17FEABCA05AF73 CC94
61850 Tested Aspects:	Sampled Values, Server	Vendor Artifact File Name:	
Company:	Siemens AG	Vendor Artifact Hash:	
Address:	Wernerwerkdammm 5 13629 Berlin Germany	Umbrella Organization:	
Product:	7VU85 High Speed Busbar Transfer	Optional Reservation Test:	Yes
HW Version:		Serial Number:	
SW Version:	Firmware version: V09.40	Publisher Legacy Variants:	F12800S8I14U4, F15360S8I4U4, F4000S1I4U4, F4800S1I4U4
Key Words:	Relay	Publisher Preferred Rates:	F14400S6, F4800S2
Test Procedure Version:	1.2	Publisher Preferred Variants:	F4800S2I16U16, F14400S6I12U12
IEC 61850 Blocks Certified:	Basic Exchange (B1 a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Sampled Value Publish (11a), Sampled Value Subscribe (11b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time sync PTP (B13b), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	F12800S8I14U4, F15360S8I4U4, F4000S1I4U4, F4800S1I4U4
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	F4800S2I16U16
Approval Date:	02/14/2023	Subscriber Preferred Rates:	F4800S2
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1, 61869-9		
Current Test Lab Name:	DNV Netherlands (A)		
Description SIPROTEC 5 - 7VU85 High Speed Busbar Transfer with three IO202			

History

#1 - 02/14/2023 12:24 PM - Herbert Falk

- Publisher Preferred Rates F14400S6, F4800S2 added

- Publisher Preferred Rates deleted (-)

- Subscriber Preferred Rates F14400S6, F4800S2 added

- Subscriber Preferred Rates deleted (-)

#2 - 02/14/2023 12:29 PM - Herbert Falk

- Approval Date set to 02/14/2023

- Publisher Preferred Variants set to F4800S2I16U16, F14400S6I12U12

- Subscriber Preferred Variants set to F4800S2I16U16

- Subscriber Preferred Rates deleted (F14400S6)

#3 - 02/05/2024 08:52 AM - Herbert Falk

- 61850 Tested Aspects Sampled Values added

Files

23-2512_DNV_Siemens_7VU85_ServerEd2Amd1_Certificate.pdf	100 KB	02/14/2023	Herbert Falk
---	--------	------------	--------------