

## Server - Issues #6269

### sSrv9, sSrv10: change Table 3 to Table D.1 reference

02/21/2023 09:45 AM - Michael Haecker

<b>Status:</b> Closed	<b>Due date:</b> 03/21/2023
<b>Priority:</b> Normal	
<b>Assignee:</b> Richard Schimmel	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b> TP1.3
<b>Clause Reference:</b>	<b>Test Case ID:</b> sSrv9, sSrv10, sSrv11
<b>61850 Standard:</b> 7-2	<b>Closed Reason:</b> --Not Set--
<b>Triggering Tissue:</b>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b>	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b> Ed2.1 TP1.2	

#### Description

In sSrv9 "Semantic of measured value (MV, CMV, WYE, DEL, SEQ" we find the following references: "IEC 61850-7-3 Subclause 6.2, 6.3, 6.4, 6.5 and 7.4.2, Table 3"

Reference to IEC 61850-7-3 Table 3 "Attributes of ValWithTrans" does not make sense here.

In Part 7-3 Ed.2 there was a Table 3 "Relation of the detailed quality identifiers with invalid or questionable quality" which fits. This table is moved to IEC 61850-7-2 Ed.2.1 Table D.1.

Propose to update the reference.

#### History

##### #1 - 03/07/2023 09:17 AM - IEC 61850 TPWG

- Due date set to 03/21/2023

- Status changed from New to In Progress

##### #2 - 03/21/2023 07:13 AM - Richard Schimmel

- Subject changed from sSrv9 : Wrong reference to a table in the standard to sSrv9, sSrv10: change Table 3 to Table D.1 reference

- Status changed from In Progress to Resolved

- Initial Test Document set to Ed2.1 TP1.2

- Test Case ID set to sSrv9, sSrv10, sSrv11

Agree to update the references and expected result in sSrv9, sSrv10, sSrv11, [sSrv15]:

- remove part 7-3 Table 3

- add part 7-2 Table D.1

##### #3 - 03/01/2024 10:01 AM - Richard Schimmel

- Status changed from Resolved to Closed

- Updated Test Document set to TP1.3