IEC 61850 Certificate - IEC 61850 Certificate #6271

SUR-K220 Protection IED

02/22/2023 08:00 AM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Test Document:**	
61850 Tested Aspects:	Server	**Certificate Name:**	23TC200096_Sanion_IED_SUR-K220_Server_Ed2_KERI.pdf
Company:	Sanion Co, Ltd	**Certificate Hash:**	SHA256: 2BEB4984C1C8435CEAA50D438C4AE3DD29B1E61AF7094C9B865769F4E62D323B
Address:	13, Geomdan-ro, 114-gil, Seo-gu, Incheon, 22663, Republic of Korea	**Vendor Artifact File Name:**	
Product:	SUR-K220 Protection IED	**Vendor Artifact Hash:**	
HW Version:	MPU: 1.00 /DSP:1.00	**Umbrella Organization:**	
SW Version:	IEC 61850 version: 1.00	**Optional Reservation Test:**	Yes
Key Words:	Relay	**Serial Number:**	
Test Procedure Version:	2.0.5	**Publisher Legacy Variants:**	-
IEC 61850 Blocks Certified:	Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Time Synchronization (B13)	**Publisher Preferred Rates:**	-
Certificate/Result Reviewer:	Herbert Falk	**Publisher Preferred Variants:**	
Approval Date:	02/22/2023	**Subscriber Legacy Variants:**	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Variants:**	
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)	**Subscriber Preferred Rates:**	-

Description

Protection IED (SUR-K220)

History

#1 - 02/22/2023 06:41 PM - Herbert Falk

- Current Test Lab Name changed from Korea Testing Laboratory (A) to Korea Electrotechnology Research Institute (A)

#2 - 06/01/2023 07:46 AM - Herbert Falk

- 61850 Edition Edition 2 added

- 61850 Edition deleted (Edition 2 Amd 1)

Files

23TC200096_Sanion_IED_SUR-K220_Server_Ed2_KERI.pdf	716 KB	02/22/2023	Herbert Falk