

## Server - Issues #6276

### sGop13 does not consider that dataset with maximumAttributes number of FCD may be too big for GOOSE

03/01/2023 04:13 AM - Hua Qin

<b>Status:</b>	Closed	<b>Due date:</b>	05/02/2023
<b>Priority:</b>	Normal		
<b>Assignee:</b>	Richard Schimmel		
<b>Category:</b>			
<b>Target version:</b>			
<b>Discuss in Upcoming Meeting:</b>	No	<b>Updated Test Document:</b>	TP1.3
<b>Clause Reference:</b>		<b>Test Case ID:</b>	sGop13
<b>61850 Standard:</b>		<b>Closed Reason:</b>	--Not Set--
<b>Triggering Tissue:</b>		<b>Triggering Tissue 2:</b>	
<b>Final Decision:</b>		<b>Triggering Tissue 3:</b>	
<b>Initial Test Document:</b>			
<b>Description</b> <p>redmine 652 (<a href="https://redmine.ucaiug.org/issues/652">https://redmine.ucaiug.org/issues/652</a>) adds a mandatory test case sGop13 to configure GoCB with a dataset with at least maxAttribtues number of FCD dataset elements. And it expects the DUT to send GOOSE messages.</p> <p>But this does not consider the situation that the dataset may be too big to fit into a single GOOSE message and conflict with test case sGopN2.</p> <p>The maxAttribtues is not only used for GOOSE but also for dataset used in RCB. RCB can have a very big dataset because it can send out segment but GOOSE can not.</p> <p>Suggest to update the test case with words "if accepted"</p>			

## History

### #1 - 03/07/2023 09:15 AM - IEC 61850 TPWG

- Due date set to 03/21/2023
- Status changed from New to In Progress
- Assignee set to Richard Schimmel

Needs further review.

### #2 - 03/21/2023 09:09 AM - IEC 61850 TPWG

Needs further review. sGop13 likely nonconformant.

definition of maxAttributes, particularly note at the bottom of the table in part 6 may need a TISSUE.

sGop13 effectively restricts the size of all datasets in the device to 1518 when GOOSE is supported, which seems wrong.

max PDU size has implication here also for getDataSetValues.

### #3 - 04/18/2023 08:50 AM - IEC 61850 TPWG

- Due date changed from 03/21/2023 to 05/02/2023

652 / sGop13 must be revised to consider PDU size as a limit to maxAttributes.

### #4 - 05/02/2023 06:50 AM - Richard Schimmel

- File Solution to redmine 0652 and 6276 sGop13 max dataset (2may2023).docx added

Added "not exceeding the ethernet PDU size limit"

#5 - 05/16/2023 08:26 AM - IEC 61850 TPWG

- Status changed from In Progress to Resolved

Agreed.

#6 - 03/01/2024 10:02 AM - Richard Schimmel

- Status changed from Resolved to Closed

- Updated Test Document set to TP1.3

Files

Solution to redmine 0652 and 6276 sGop13 max dataset (2may2023).docx	21.8 KB	05/02/2023	Richard Schimmel
--	---------	------------	------------------