

Server - Issues #6277

sCtl4 (stSeld) shall be mandatory in Ed2 Amend 1

03/02/2023 04:19 AM - Hua Qin

Status: Closed	Due date: 03/21/2023
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document: TP1.3
Clause Reference:	Test Case ID: sCtl4
61850 Standard:	Closed Reason: --Not Set--
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: TP1.2	
Description sSctl4 tests stSeld. In ED2 Amend 1 part 7-3, stSeld become mandatory when SBOs or/and SBOes is supported. So for sCtl4 in SBOs and SBOes section, the test case is not optional anymore. Suggest:update Table A.4.2 and certificate template.	

History

#1 - 03/07/2023 09:03 AM - IEC 61850 TPWG

- Due date set to 03/21/2023
- Status changed from New to In Progress
- Assignee set to Richard Schimmel

#2 - 03/21/2023 04:49 AM - Richard Schimmel

- Subject changed from sCtl4 shall be mandatory in ED2 amend 1 to sCtl4 (stSeld) shall be mandatory in Ed2 Amend 1
- Status changed from In Progress to Resolved

Agree change sCtl4 from conditional to mandatory in table A.4.2 and certificate template.

#3 - 03/01/2024 10:02 AM - Richard Schimmel

- Status changed from Resolved to Closed
- Updated Test Document set to TP1.3