

# IEC 61850 Certificate - IEC 61850 Certificate #6286

## Landis Gyr AG E65C CU-XE Grid Edge Gateway with S650 and E660

03/10/2023 01:17 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.5
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	23-2622_DNV_Landis+Gyr_E65C-CU-XE_E66C_ServerEd2_Certificate.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 3B3C5F1C66DD385FDB934E61E4AA9 34A3339281AC456CE0F5ED1BE882A4 AF48D
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Landis Gyr AG	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Alte Steinhauserstrasse 18 6330 Cham Switzerland	<b>Umbrella Organization:</b>	
<b>Product:</b>	Landis Gyr AG E65C CU-XE Grid Edge Gateway with S650 and E660	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	S/N: ELGZ0043571965	<b>Serial Number:</b>	
<b>SW Version:</b>	IEC 61850 version: 2.0	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Meter	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.5	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Data Set Definition (B2+), Data Sets (B2), File Transfer (B14), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	03/10/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

E65C CU-XE Grid Edge Gateway with S650 and E660 meter and E66E expansion module

### History

#1 - 03/10/2023 01:24 PM - Herbert Falk

- 61850 Edition Edition 2 added

- 61850 Edition deleted (Edition 2 Amd 1)

### Files

23-2622_DNV_Landis+Gyr_E65C-CU-XE_E66C_ServerEd2_Certificate.pdf	421KB	03/10/2023	Herbert Falk
--	-------	------------	--------------