

IEC 61850 Certificate - IEC 61850 Certificate #6287

Teamware CCI-Central Plant controller

03/10/2023 01:23 PM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.5
Priority:	Normal	Certificate Name:	22-3434_DNV_Teamware s.r.l_CCI-Central Plant controller_ServerEd2_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 1E6D01D3555962966D9AE6DBD73BA23568DBFED78BCB62CD90BC2A9257FA1A9D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Teamware s.r.l	Vendor Artifact Hash:	
Address:	Via Pindaro 19 20128 Milan Italy	Umbrella Organization:	
Product:	CCI-Central Plant controller	Optional Reservation Test:	Yes
HW Version:	S/N: 1015122100010	Serial Number:	
SW Version:	1.1	Publisher Legacy Variants:	-
Key Words:	Meter	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	03/10/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

Files

22-3434_DNV_Teamware s.r.l_CCI-Central Plant controller_ServerEd2_Certificate.pdf 03/10/2023

Herbert Falk