IEC 61850 Certificate - IEC 61850 Certificate #6288

HSC RTU for Industrial Automation and Control Systems

03/10/2023 01:33 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	23-2657_DNV_Higeco_HSC_ServerEd2_Certificate.pdf
61850 Tested Aspects:	Server	**Certificate Hash:**	SHA256: 168632BE51079819A313A2B75E2E57C9F5B646FE1AFC173A356AF3AF764FE846
Company:	Higeco Srl	**Vendor Artifact File Name:**	
Address:	HW R&D Viale Europa 71 32100 Belluno Italy	**Vendor Artifact Hash:**	
Product:	HSC RTU for Industrial Automation and Control Systems	**Umbrella Organization:**	
HW Version:	HSC 110 C	**Optional Reservation Test:**	No
SW Version:	IEC 61850 version: HSC 110C V5.1	**Serial Number:**	
Key Words:	RTU	**Publisher Legacy Variants:**	-
Test Procedure Version:	2.0.6	**Publisher Preferred Rates:**	-
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	Herbert Falk	**Subscriber Legacy Variants:**	-
Approval Date:	03/10/2023	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	-
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:	Edition 2 Server Test Procedures version 2.0.6		

Description

Files

23-2657_DNV_Higeco_HSC_ServerEd2_Certificate.pdf	124 KB	03/10/2023	Herbert Falk