

IEC 61850 Certificate - IEC 61850 Certificate #6289

PST 671U

03/15/2023 02:44 PM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-D 002427 0006_SAC_PST671U_IEC61850Ed2.0_Server_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 0195B5CC7AF9A431A3F54F82FDCA76 A4C3A163F85F12F85348E674F429EA AEF1
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GUODIAN NANJING AUTOMATION CO., LTD. /NANJING SAC POWER GRID AUTOMATION CO., LTD	Vendor Artifact Hash:	
Address:	No.39, Shuige Road, Jiangning Development Zone, 211153, Nanjing, PEOPLE'S REPUBLIC OF CHINA	Umbrella Organization:	
Product:	PST 671U	Optional Reservation Test:	Yes
HW Version:	HW1.0-K	Serial Number:	
SW Version:	6.01.00.01	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	03/15/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		
Description			

Files

23-D 002427 0006_SAC_PST671U_IEC61850Ed2.0_Server_Certificate.pdf	195 KB	03/15/2023	Herbert Falk
---	--------	------------	--------------