

## Server - Issues #6291

### sGos13 - Remove/deprecate PIXIT Gs12

03/17/2023 05:47 AM - Richard Schimmel

<b>Status:</b> Closed	<b>Due date:</b>
<b>Priority:</b> Normal	
<b>Assignee:</b> Richard Schimmel	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b> TP1.3
<b>Clause Reference:</b> Table A.4.2	<b>Test Case ID:</b> sGos13
<b>61850 Standard:</b>	<b>Closed Reason:</b> --Not Set--
<b>Triggering Tissue:</b>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b>	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b> Ed2.1 TP1.2	
<b>Description</b>	
Table A.4.2 has condition PIXIT Gs12 for sGos13. But it is defined in SCL if security publish/subscribe is supported by the device. Proposal: change the condition to SCL-ClientServices McSecurity=True.	

#### History

##### #1 - 03/21/2023 07:38 AM - Richard Schimmel

- Subject changed from sGos13 - change condition from PIXIT Gs12 to SCL McSecurity=true to sGos13 - Remove/deprecate PIXIT Gs12

The condition is updated in Table A.4.2 but PIXIT Gs12 is still referenced in the detailed test procedure sGos13. PIXIT Gs12 entry shall be deprecated.

##### #2 - 03/21/2023 08:07 AM - IEC 61850 TPWG

- Status changed from New to Resolved

- Assignee set to Richard Schimmel

PIXIT Gs12 entry shall be deprecated and removed from sGos13.

##### #3 - 03/01/2024 10:04 AM - Richard Schimmel

- Status changed from Resolved to Closed

- Updated Test Document set to TP1.3