

# IEC 61850 Certificate - IEC 61850 Certificate #6292

## Siemens 7UT86 TRANSFORMER DIFFERENTIAL PROTECTION

03/17/2023 08:14 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	CPRI-Siemens-CPRI BLRSGRL23TC000 2.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: C01FF644033BE8020824D83CDE8469 E49FC5E1101C719878F960CBD63BC4 4A1F
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	SIEMENS LTD	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Verna Plot No - L6, Verna Industrial Estate, Opp. Goa - Mumbai highway, Verna, South Goa - 403722 INDI	<b>Umbrella Organization:</b>	
<b>Product:</b>	Siemens 7UT86 TRANSFORMER DIFFERENTIAL PROTECTION	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	7UT86 with CP300	<b>Serial Number:</b>	
<b>SW Version:</b>	V09.40	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Differential, Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	03/17/2023	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Central Power Research Institute India (A)		
<b>Description</b>			
TRANSFORMER DIFFERENTIAL PROTECTION			

### Files

CPRI-Siemens-CPRI BLRSGRL23TC0002.pdf	968 KB	03/17/2023	Herbert Falk
---------------------------------------	--------	------------	--------------