

WG14 Part 9 Issues - CIM Issues #6297

New Event code needed in Part 9 for DC Voltage

03/22/2023 08:24 AM - David Haynes

<b>Status:</b>	New	
<b>Priority:</b>	Normal	
<b>Target version:</b>		
<b>Author/Contact Info:</b>	dhaynes@hubbell.com	<b>Standard(s):</b> 61968-9
<b>Base Release:</b>		<b>Version:</b> 4
<b>Solution to be Applied To:</b>		<b>Clause:</b> Annex E
<b>Solution Version:</b>		<b>Sub-Clause:</b> E.7
<b>Solution Applied By:</b>		<b>Paragraph:</b>
<b>Completion Date:</b>		<b>Table:</b>
<b>CIM Keywords:</b>	61968-Metering	<b>Originally Closed in Version:</b>
<b>Breaking Change:</b>		<b>Origination Date:</b>
<b>Breaking Change Description:</b>		<b>Origination ID:</b>
<b>CIM Impacted Groups:</b>	WG14	<b>Originally Assigned To:</b>
<b>Requestor:</b>		
<b>Description</b> Part 9 needs a way to indicate that a DC Voltage has been detected (at the AC Revenue meter) and that the DC Voltage has ceased.		
<b>Proposed Solution</b> Part 9 needs, in Annex E, EndDeviceSubDomain, a code to indicate "DC Voltage" as opposed to "Voltage". This would be adding an enumeration to the existing list.		

History

- #1 - 03/22/2023 08:48 AM - David Haynes
- Subject changed from New Event code needed in Part 9 to New Event code needed in Part 9 for DC Voltage
- #2 - 04/20/2023 09:54 AM - Ricardo Lopez
- Where does this edit show up?