

IEC 61850 Certificate - IEC 61850 Certificate #6300

DW-IPC-A-50000 SA LID (Substation Automation Local Information processing Device)

03/26/2023 10:38 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.
Priority:	Normal	Certificate Name:	23-014055-04-2_Dowoo_SA LID_Server_Ed2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 182ABC8A70E99B6C9F00B987D8F749 E66D8D27207A2EFD014346B559847A 99DB
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	DoWoo Digitech. Co., Ltd	Vendor Artifact Hash:	
Address:	A-708, Ssangyong IT Twin-tower, Dunchon-daero, Jungwon-gu, Seongnam-si, Gyeonggi-do, Republic of Korea	Umbrella Organization:	
Product:	DW-IPC-A-50000	Optional Reservation Test:	Yes
HW Version:	DoWoo Digitech DW-IPC-A-50000	Serial Number:	
SW Version:	1.0.0	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	03/26/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
SA LID (Substation Automation Local Information processing Device)			

Files

23-014055-04-2_Dowoo_SA LID_Server_Ed2_Certification_KTL.pdf	84.2 KB	03/26/2023	Herbert Falk
--	---------	------------	--------------