

IEC 61850 Certificate - IEC 61850 Certificate #6301

REC670 Bay control

03/27/2023 10:42 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 with Amendment 1 Test Procedures 1.1
Priority:	Normal	Certificate Name:	23-2620_DNV_Hitachi_REC670_Server Ed2Amd1_Certificate.pdf
61850 Edition:	Edition 2 Amd 1	Certificate Hash:	SHA256: 4CB47FE9BF79B34800009E2D3D53F E6A208C6739712B995AC1A57603E030 56A
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Hitachi Energy Sweden AB	Vendor Artifact Hash:	
Address:	GA Products S-721 59 Västerås Sweden	Umbrella Organization:	
Product:	REC670 Bay control	Optional Reservation Test:	No
HW Version:	2.2.6	Serial Number:	
SW Version:	2.2.19.1	Publisher Legacy Variants:	-
Key Words:	Bay Controller	Publisher Preferred Rates:	-
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time sync PTP (B13b), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	03/27/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

Files

23-2620_DNV_Hitachi_REC670_ServerEd2Amd1_Certificate.pdf	117 KB	03/27/2023	Herbert Falk
--	--------	------------	--------------