

IEC 61850 Certificate - IEC 61850 Certificate #6302

REC670 Bay control

03/27/2023 10:47 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-2630_DNV_Hitachi_REC670&variants_ServerEd2_Certificate.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 48920A7E067998261055ABFF0EB33B C9B30E0341EBD406DE67A1BE5AF153 BDB5
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Hitachi Energy Sweden AB	Vendor Artifact Hash:	
Address:	GA Products S-721 59 Västerås Sweden	Umbrella Organization:	
Product:	REC670 Bay control	Optional Reservation Test:	No
HW Version:	2.2.19.1	Serial Number:	
SW Version:	2.2.6	Publisher Legacy Variants:	-
Key Words:	Bay Controller	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	03/27/2023	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

Files

23-2630_DNV_Hitachi_REC670&variants_ServerEd2_Certificate.pdf 123 KB

03/27/2023

Herbert Falk